




Materials/Finishes:	Copper Plated Carbon Steel (310CT)
Variants:	Copper Epoxy Coated <i>Copper Gard</i> : Imported (310CTI)
Service:	Designed for the suspension of non-insulated, stationary copper lines.
Approvals:	Complies with Federal Specification WW-H-171-E (Type# 10), A-A-1192 A (Type# 10) and Manufacturers' Standardization Society MSS SP-58 and SP-69 (Type# 10).
Ordering:	Specify figure number, finish and tube size.
Notes:	N/A

TUBE SIZE	TUBE OD	MATERIAL SIZE	A	B	C	E	F	G	WGT EACH (lbs)	MAX REC LOAD (lbs)
1/2	0.625	18ga x 5/8	3/8	2-11/16	3	1-13/16	1-1/2	7/8	0.070	300
3/4	0.875	18ga x 5/8	3/8	2-1/2	2-15/16	1-5/8	1-3/16	7/8	0.070	300
1	1.125	18ga x 5/8	3/8	2-7/16	3	1-9/16	1	7/8	0.070	300
1-1/4	1.375	18ga x 5/8	3/8	2-1/2	3-3/16	1-5/8	1-5/16	7/8	0.080	300
1-1/2	1.625	18ga x 5/8	3/8	2-9/16	3-3/8	1-11/16	7/8	7/8	0.085	300
2	2.125	18ga x 5/8	3/8	3-5/16	4-3/8	2-7/16	1-3/8	7/8	0.100	300
2-1/2	2.625	14ga x 1	1/2	3-7/8	5-9/16	2-13/16	1-1/2	1-1/16	0.310	525
3	3.125	14ga x 1	1/2	4-3/16	5-3/4	3-1/8	1-9/16	1-1/16	0.345	525
3-1/2	3.625	14ga x 1	1/2	4-9/16	6-3/8	3-1/2	1-11/16	1-1/16	0.375	525
4	4.125	14ga x 1	1/2	4-13/16	6-15/16	3-3/4	1-11/16	1-1/16	0.410	650
5	5.125	14ga x 1	1/2	5-3/16	7-13/16	4-1/8	1-9/16	1-1/16	0.475	1000
6	6.125	14ga x 1	1/2	5-11/16	8-15/16	4-5/8	1-9/16	1-1/16	0.530	1000

PROJECT INFORMATION			APPROVAL STAMP	
Project:			Notes:	
Address:				
Contractor:				
Engineer:				
Date:				
Approved	Approved as Noted	Not Approved		