




NOTES:

1. THE ANSI Z358.1-2009 STANDARD SPECIFIES EYEWASH NOZZLE HEIGHTS TO BE 83.8cm (33 IN.) TO 114.3cm (45 IN.) ABOVE THE FLOOR. CENTERLINE OF EYEWASH HEADS MUST BE 15.2cm (6 IN.) MIN. AWAY FROM WALL OR NEAREST OBSTRUCTION.
2. DIMENSIONS MAY VARY $\pm 1/2$ " [13mm].

 Haws®				1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWSO.COM WEBSITE: WWW.HAWSO.COM			
				ECN NO. REVISED PER BY: MODEL(S) ECN: 5005 HM DATE: 3/19/92 CHKD.: RVH DRAWN: C HAYES APPROVED: FV DATE: 06/25/15 SCALE: 1:1 DRAWING TYPE: INSTALLATION SIZE: A SHEET 1 OF 1			
7612LH LEFT HAND DECK MTD EYE/FACE WASH				PART NUMBER 0002080065.D REVISION 10			